

**SSCH 7.3X1.2X1000****Weidmüller Interfaces GmbH & Co. KG**

Postfach 3030

32760 Detmold

Tel. +49 5231 14-0

Fax. +49 5231 14-2083

info@weidmueller.com

www.weidmueller.com



Of all the metals used, copper has the best electrical conductivity, which results in the highest short-circuit resistance. This makes the copper busbar the most widely used variant.

**General ordering data**

|            |                             |
|------------|-----------------------------|
| Version    | Accessories, Busbar, Copper |
| Order No.  | <a href="#">1071200000</a>  |
| Type       | SSCH 7.3X1.2X1000           |
| GTIN (EAN) | 4008190279172               |
| Qty.       | 1 m                         |

**SSCH 7.3X1.2X1000**

**Weidmüller Interfaces GmbH & Co. KG**

Postfach 3030

32760 Detmold

Tel. +49 5231 14-0

Fax. +49 5231 14-2083

[info@weidmueller.com](mailto:info@weidmueller.com)

[www.weidmueller.com](http://www.weidmueller.com)

**Technical data**

**Dimensions and weights**

|            |          |                 |            |
|------------|----------|-----------------|------------|
| Depth      | 1.2 mm   | Depth (inches)  | 0.047 inch |
| Height     | 1,000 mm | Height (inches) | 39.37 inch |
| Width      | 7.3 mm   | Width (inches)  | 0.287 inch |
| Net weight | 77 g     |                 |            |

**Material data**

|          |        |                |            |
|----------|--------|----------------|------------|
| Material | Copper | Surface finish | galvanized |
| Colour   | silver |                |            |

**Additional technical data**

|                     |                 |
|---------------------|-----------------|
| Installation advice | Direct mounting |
|---------------------|-----------------|

**General**

|                     |                 |                |            |
|---------------------|-----------------|----------------|------------|
| Installation advice | Direct mounting | Surface finish | galvanized |
|---------------------|-----------------|----------------|------------|

**Classifications**

|             |             |             |             |
|-------------|-------------|-------------|-------------|
| ETIM 6.0    | EC002848    | ETIM 7.0    | EC002848    |
| ETIM 8.0    | EC002848    | ECLASS 9.0  | 27-14-11-92 |
| ECLASS 9.1  | 27-14-11-92 | ECLASS 10.0 | 27-14-11-92 |
| ECLASS 11.0 | 27-14-11-92 | ECLASS 12.0 | 27-14-11-92 |

**Approvals**

Approvals



|      |         |
|------|---------|
| ROHS | Conform |
|------|---------|

**Downloads**

|   |  |
|---|--|
| Approval/Certificate/Document of Conformity | <a href="#">EAC certificate</a>                    |
| Engineering Data                            | <a href="#">CAD data – STEP</a>                    |
| User Documentation                          | <a href="#">Storage Conditions Terminal Blocks</a> |
| Catalogues                                  | <a href="#">Catalogues in PDF-format</a>           |
| Brochures                                   | <a href="#">CAT 1 TERM 16/17 EN</a>                |