

VT MASTER**Weidmüller Interface GmbH & Co. KG**

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com



The main function of the voltage tester is to establish if voltage is present. A 2-pole voltage tester is the only approved testing instrument that fulfils the requirements of work protection regulations.

- with LED-Display
- acc. to VDE standard
- high peak voltage strength
- the right tester for every application

General ordering data

Version	Testing tools, 2-pole voltage tester type 1157
Order No.	9918880000
Type	VT MASTER
GTIN (EAN)	4032248405763
Qty.	1 pc(s).

Creation date March 1, 2023 3:05:45 PM CET

Catalogue status 18.02.2023 / We reserve the right to make technical changes.

VT MASTER

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

Technical data

Dimensions and weights

Depth	60 mm	Depth (inches)	2.362 inch
Height	28 mm	Height (inches)	1.102 inch
Width	235 mm	Width (inches)	9.252 inch
Net weight	272 g		

Technical data

Description of article	Voltage tester up to 690 V / 100 Hz LED
------------------------	---

Measuring and testing devices

AC voltage display	12, 24, 50, 120, 230, 400, 690 V	AC voltage measuring range	12-690 V
Battery type	1.5 V type AAA battery	Continuity test	Yes - visual + acoustic
DC voltage display	12, 24, 50, 120, 230, 400, 690 V	DC voltage measuring range	690 V
Display	LED	Frequency range, max.	65 Hz
Frequency range, min.	0 Hz	Insulation test	6 kV
Load switchable	No	Measuring range category	CAT III 600 V
Peak voltage resistance	6 kV	Phase sequence display	No
Protection degree	IP54	Rated voltage, max.	690 V AC/DC
Rated voltage, min.	12 V	Tested and approved according to	IEC 61243-3:2014 (DIN EN 61243-3:2015-08)
Working temperature, max.	55 °C	Working temperature, min.	-15 °C

Classifications

ETIM 6.0	EC000494	ETIM 7.0	EC000494
ETIM 8.0	EC000494	ECLASS 9.0	27-20-03-08
ECLASS 9.1	27-20-03-08	ECLASS 10.0	27-20-03-08
ECLASS 11.0	27-20-03-08	ECLASS 12.0	27-20-03-08

Environmental Product Compliance

REACH SVHC	Lead 7439-92-1
SCIP	b05b5122-6117-4cb0-b28c-df32f921fa36

Approvals

Approvals



ROHS Conform

Downloads

Approval/Certificate/Document of Conformity	9918860000_DECLARATION_OF_CONFORMITY.pdf
Product Change Notification	PCN-PW641110-20180410-00-A EN PCN-PW641110-20180410-00-A DE
User Documentation	BANL_manual 2pol Tester
Catalogues	Catalogues in PDF-format
Brochures	

Creation date March 1, 2023 3:05:45 PM CET

Catalogue status 18.02.2023 / We reserve the right to make technical changes.